



Exit Doors

Download additional self-inspection checklists at <http://engineering.tamu.edu/safety/>

Date _____
 Inspector _____
 Faculty/PI _____

Room No. _____
 Location _____
 Dept. _____

Items for evaluation	Yes	No	Comments	Action to be taken
Are doors which are required to serve as exits, designed and constructed so that the way of exit travel is obvious and direct?				
Are windows which could be mistaken for exit doors, made inaccessible by means of barriers or railings?				
Are exit doors openable from the direction of exit travel without the use of a key or any special knowledge or effort when the building is occupied?				
Are revolving, sliding, or overhead doors prohibited from serving as required exit doors?				
Where panic hardware is installed on a required exit door, will it allow the door to open by applying a force of 15 pounds or less, in the direction of the exit traffic?				
Are doors on cold storage rooms provided with an inside release mechanism which will release the latch and open the door, even if it's padlocked or otherwise locked on the outside?				
Where exit doors open directly onto any street, alley, or other area where vehicles may be operated, are adequate barriers and warnings provided to prevent employees stepping into the path of traffic?				
Are doors that swing in both directions, and are located between rooms where there is frequent traffic, provided with viewing panels in each door?				
Is the required Emergency Contact Information posted on the outside of entry doors to this work area?(Includes :Labs, shops, storage and other hazardous locations)				