



Fire Protection

Download additional self-inspection checklists at <http://engineering.tamu.edu/safety/>

Date _____
 Inspector _____
 Faculty/PI _____

Room No. _____
 Location _____
 Dept. _____

Items for evaluation	Yes	No	Comments	Action to be taken
Is your local fire department well acquainted with your facilities, its location, and specific hazards?				
If you have a fire Alarm system, is it certified as required?				
If you have a fire Alarm system, is it tested at least annually?				
If you have interior stand pipes and valves, are they inspected regularly?				
If you have outside private fire hydrants, are they flushed at least once a year, and on a routine preventive maintenance schedule?				
Are fire doors and shutters in good operating condition?				
Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?				
Are fire door and shutter fusible links in place?				
Are automatic sprinkler system water control valves, air and water pressure checked weekly/periodically as required?				
Is the maintenance of automatic sprinkler systems assigned to responsible persons, or to a sprinkler contractor?				
Are sprinkler heads protected by metal guards, when exposed to potential physical damage?				
Is proper clearance maintained below sprinkler heads?				

Items for evaluation	Yes	No	Comments	Action to be taken
Are portable fire extinguishers provided in adequate number and type?				
Are fire extinguishers mounted in readily accessible locations?				
Are fire extinguishers recharged regularly and noted on the inspection tag?				
Are employees periodically instructed in the use of extinguishers and fire protection procedures?				